

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING NO.** 7135-0801:118 Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Radionics, Div. Detection Systems Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199  
Contact: Frank Mioduszewski \*(585) 223-4060

**DESIGN:** Models D448, D448W, D449, D449W, D452, D453 and D453A horns and horn/strobes.  
Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as audible and audible/visual device for use with separately listed compatible control units.

These units cannot produce the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. If required, the appliances must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Combined 7135-0801:140 into 7135-0801:118

**XLF:** 7135-0785:115

\*Rev. 05-30-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 30, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**  
**Program Manager**